

Time Stamp	Apparent Power Demand (kVA)	Average Current (A)	Average L-L Voltage (V)	L1 Current (A)	L1-L2 Voltage (V)	L2 Current (A)	L2-L3 Voltage (V)	L3 Current (A)	L3-L1 Voltage (V)	Percent Current Unbalance (%)	Percent Voltage Unbalance (%)	Reactive Power Demand (kVAR)	Real Energy Net (kWh)	Real Power Demand (kW)	Distortion Power Factor	Total True Power Factor
1/31/2011 10:15	2926.2	134	13361	137.5	13432.6	133.1	13192.8	131.3	13457.5	2.7	1.2	2246	12365530	1829.9	100	-72
1/31/2011 10:00	1783.9	161.8	14010.3	94.1	13440.9	90.1	13192.8	89.4	13457.5	3.2	0.8	1205.1	12363967	970.8	100	-67
1/31/2011 9:45	2388.9	30	13877.9	108.9	13775.9	106.1	13531.9	106.2	13796.6	1.4	0.8	548	12363724	1056.4	100	-67
1/31/2011 9:30	2065	30.2	13737.3	120.3	13709.7	120.1	13527.8	120.5	13821.4	0.7	1.2	2773.1	12363460	1136.7	100	-44
1/31/2011 9:15	2902.9	65.8	13795.2	104.2	14077.8	100.2	13800.7	101	14061.3	2	1.1	1995.2	12363176	1764.8	99	-29
1/31/2011 9:00	2795.2	33	13933.1	86.5	14177.1	84.5	13949.6	83.1	14185.3	2.4	0.5	1470.1	12362734	1245.4	100	-40
1/31/2011 8:45	2388.9	98.6	13905.5	100.8	13966.1	97	13788.3	98	13962	2.6	0.7	2105.8	12363754	1056.4	100	-28
1/31/2011 8:30	2065	29.9	13937.2	32.1	14069.5	29.9	13813.1	27.7	13928.9	0.5	0.9	1677.1	12363511	1136.7	99	-62
1/31/2011 8:15	2902.9	102.6	13836.6	104.3	13974.4	103.2	13705.6	100.4	13829.7	2.6	1.1	2267.9	12363245	1764.8	100	-68
1/31/2011 8:00	2795.2	163.8	13788.3	165.5	13862.7	164.9	13734.5	161.1	13767.6	1.7	0.6	2479.1	12362817	1245.4	100	-64
1/31/2011 7:45	1070.5	162.5	13866.9	159.7	13895.8	161.3	13792.4	166.5	13912.4	2.7	0.5	914.7	12362490	497.9	99	-41
1/31/2011 7:30	813	29.5	13791.1	30.9	13846.2	29.3	13742.8	28.2	13784.2	8.1	0.4	613.3	12362318	533	100	-64
1/31/2011 7:15	1912.3	46.3	13764.9	47.9	13821.4	46.2	13718	44.7	13755.2	4.4	0.5	1374.9	12362202	1327.3	100	-69
1/31/2011 7:00	2839.7	131.1	13632.5	133.2	13680.8	132.2	13593.9	127.8	13622.9	1.9	0.5	2317.1	12361924	1603	100	-69
1/31/2011 6:45	2591.7	124.1	13657.3	127.3	13734.5	124.9	13610.5	120.1	13627	2.2	0.5	1916.8	12361484	1733.3	100	-43
1/31/2011 6:30	2824.1	80.4	13676.6	79.6	13751.1	83.7	13622.9	78	13656	3	0.4	2291	12361106	1614.1	100	-39
1/31/2011 6:15	2730.7	167.7	13518.1	167.7	13565	167.9	13486.4	167.4	13502.9	0.7	0.2	2210.8	12360658	1560.4	100	-52
1/31/2011 6:00	948.8	76.8	13778.7	80.7	13833.8	77.5	13672.5	72.2	13829.7	6.9	0.6	722	12360259	612.2	99	-70
1/31/2011 5:45	1313	33.4	13880.7	35.8	13933.1	32.6	13771.8	31.8	13937.2	8.9	0.8	969.1	12360074	884.4	100	-62
1/31/2011 5:30	2332.1	74.8	13909.6	79.1	13995.1	75.8	13792.4	69.5	13941.3	6.7	1.1	1755.9	12359883	1515.9	99	-68
1/31/2011 5:15	4050.4	157.1	13800.7	158.6	13879.3	158.2	13680.8	154.5	13842.1	2.9	0.7	3456.7	12359523	2080.5	100	-68
1/31/2011 5:00	2719.4	203.2	13620.1	201.8	13680.8	203	13507.1	205	13672.5	0.9	0.9	2078.4	12358992	1722.6	99	-51
1/31/2011 4:45	2773.9	98.6	13904.1	102.5	13962	98	13800.7	95.4	13949.6	3.8	0.9	2271.1	12358560	1565.7	100	-55
1/31/2011 4:30	1858.5	73.5	14000.6	78	14057.1	73.8	13900	68.9	14044.7	8	0.7	1535.9	12358163	1023.2	99	-69
1/31/2011 4:15	942.7	31.3	14172.9	34.3	14201.9	29.7	14032.3	29.9	14284.6	9.4	0.9	758.8	12357874	553.9	100	-62
1/31/2011 4:00	749.3	109.8	13963.4	111.4	14048.9	108.9	13837.9	109.1	14003.4	0.8	0.6	587.2	12357749	465.3	100	-56
1/31/2011 3:45	750	30.9	14131.6	33.2	14189.5	30.2	14024	29.4	14181.2	7.8	0.8	587.9	12357619	465.7	100	-63
1/31/2011 3:30	751.4	30.9	14127.4	33.2	14181.2	30.1	14028.2	29.4	14172.9	6.8	0.6	589.6	12357503	465.9	100	-62
1/31/2011 3:15	1138.5	31.1	14148.1	32.3	14197.7	31	14127.4	29.9	14119.2	5.8	0.4	855.4	12357387	749.9	100	-62
1/31/2011 3:00	1327.2	69.2	14098.5	69.7	14172.9	71.5	14065.4	66.5	14057.1	7.3	0.4	979.8	12357231	893.3	99	-65
1/31/2011 2:45	816.3	33.3	14156.4	34.5	14201.9	33.2	14135.7	32.2	14131.6	1.8	0.2	644.8	12356977	500.6	100	-62
1/31/2011 2:30	959.6	33.1	14149.5	34.2	14139.8	32.4	14148.1	32.6	14160.5	3.5	0.1	736.9	12356852	613.5	100	-61
1/31/2011 2:15	1417.2	45.4	14168.8	47	14139.8	43.9	14148.1	45.2	14218.4	2.6	0.2	1045.5	12356717	953.5	100	-67
1/31/2011 2:00	841.1	33.4	14237.7	34.8	14214.3	32.2	14222.6	33.1	14276.3	3.6	0.4	674.7	12356461	502.3	100	-60
1/31/2011 1:45	890.8	33.8	14314.9	35.6	14317.7	32.7	14272.2	33	14354.9	7.8	0.3	703	12356335	545.8	100	-59
1/31/2011 1:30	1045.4	33.7	14258.4	35.1	14297	33.4	14226.7	32.6	14251.5	5.4	0.5	800.8	12356209	670.5	100	-60
1/31/2011 1:15	2108.9	35.7	14247.4	37	14297	35.6	14222.6	34.5	14222.6	4.1	0.2	1689.5	12356032	1240.6	100	-61
1/31/2011 1:00	2347.7	37.4	14272.2	38.9	14305.3	37	14243.2	36.2	14268	4.2	0.3	1908.5	12355764	1320	100	-59
1/31/2011 0:45	3000.5	160.5	14000.6	159.7	14053	159.5	13970.3	162.3	13978.5	1.8	0.4	2589.7	12355408	1472	99	-65
1/31/2011 0:30	2307.6	205.1	13915.1	199.9	13978.5	204.8	13900	210.8	13866.9	3.9	0.4	2087.8	12355080	951.3	99	-52
1/31/2011 0:15	864.6	148.6	14021.3	146.1	14090.2	148.8	13970.3	151	14003.4	1.4	0.7	688.3	12354803	521.7	99	-38
1/31/2011 0:00	845.2	33.7	14281.8	34.8	14325.9	33.7	14263.9	32.6	14255.6	8	0.3	663.9	12354655	523	100	-61
1/30/2011 23:45	669.6	34	14270.8	35.6	14251.5	32.9	14251.5	33.5	14309.4	7	0.6	501.9	12354525	442.3	100	-62
1/30/2011 23:30	522.8	21	14292.9	22.2	14263.9	20.2	14272.2	20.5	14342.5	13.2	0.3	390.5	12354407	347.6	100	-67
1/30/2011 23:15	525.9	21	14309.4	22.3	14317.7	20.4	14263.9	20.2	14346.6	5.7	0.7	393.9	12354320	348.4	100	-66
1/30/2011 23:00	522.7	21.2	14403.1	22.7	14392.1	20.5	14354.9	20.6	14462.4	7.1	0.2	389.9	12354233	348	100	-65
1/30/2011 22:45	515.3	20.9	14294.2	22.2	14268	20.2	14268	20.4	14346.6	11.3	0.5	384.2	12354146	343.5	100	-66
1/30/2011 22:30	477.6	20	14257	21.2	14226.7	19.2	14226.7	19.7	14317.7	7.6	0.3	353	12354059	321.8	100	-67